



**Institute of Ceramics  
and Building  
Materials**

Division of Glass and Building Materials in Krakow

31-983 Krakow, Cementowa 8 Str.

tel.: +48 12 683 79 00

fax: +48 12 683 79 01

www.icimb.pl

info\_krakow@icimb.pl

**Department of Gypsum and Building Chemistry**

tel.: +48 12 683 79 77

m.niziurska@icimb.pl



**AB 054**

Sponsor: River Power s.r.o., Hlubinská 1378/36, 702 00 Ostrava, Czech Republic

Sample: INSULATING PAINT PSC - 250T

**TEST CERTIFICATE (16.02.2018 version 2.0)**

1) Water - vapor permeability PN-EN ISO 7783:2011	<b>6,2 g/m<sup>2</sup>d</b>
2) Water permeability PN-EN 1062:2008	
10 min	<b>0,01 m<sup>2</sup>·h<sup>0,5</sup></b>
30 min	<b>0,01 m<sup>2</sup>·h<sup>0,5</sup></b>
1 h	<b>0,00 m<sup>2</sup>·h<sup>0,5</sup></b>
2 h	<b>0,01 m<sup>2</sup>·h<sup>0,5</sup></b>
3 h	<b>0,01 m<sup>2</sup>·h<sup>0,5</sup></b>
6h	<b>0,00 m<sup>2</sup>·h<sup>0,5</sup></b>
24 h	<b>0,01 m<sup>2</sup>·h<sup>0,5</sup></b>
3) Adhesion to substrate PN-EN 1542:2000	<b>1,0 MPa</b>
4) Thermal stability PN-EN 13678-3:2002	<b>2,0 MPa</b>

  
.....  
Verification

Z-ca Kierownika Zakładu  
Gipsu i Chemii Budowlanej

  
**mgr inż. Michał Wieczorek**

.....  
Signature of entitled person